



NOTES

- (1) Fourteen gauge galvanized steel, painted.
- (2) Contractor must furnish full 3/4" plywood back.
- (3) Opening in both doors, no glass, fitted with hinged flap covers, and lockable latch.
- (4) Door shall have latch and lockable handle.

Approved Equipment		
Manufacturer	Item	Mfg Part #
Eastern-Owens	Enclosure	EOT-24
Hoffman	Enclosure	BN830ASY
Milbank	Enclosure	364812-CT3R-SP2
Nvent	Enclosure	A483612CTPNMW2
Sunwest	Enclosure	SW-1982 W2