



NOTES

- (1) Socket to be Underwriters Laboratory (UL) listed.
- (2) Socket shall be 20A class only.
- (3) Socket shall have two separate covers for meter and test switch compartments.
- (4) Latching bottom compartment shall lock both covers.
- (5) This applies to 100 and 167 kVA single-phase transformers only.
- (6) Meter shall be 4' - 5' 6" from finished grade.
- (7) Metering and instrument cabinets shall not be used to house Customer-owned equipment, such as distribution panels or other equipment, nor used as a junction box/trough for the distribution of circuits.
- (8) Customer building numbers must be permanently painted on proper meter panel.
- (9) PNM does not permit a trough ahead of meter socket.

REFERENCES

- (1) See MS-3-9.5 Single-Phase Bushing CT Meter Installation
- (2) See DM-4-11.0 Maximum Available Fault Currents

Approved Equipment		
Manufacturer	Item	Mfg Part #
Eaton	20A 6T Ringless Socket	USTS62CCH
Milbank	20A 6T Ringless Socket	UC3426-XL
Siemens	20A 6T Ringless Socket	9837-8243

For ease of checking service without interruption, PNM will no longer allow ring meter sockets as of 12/01/2013.