



## **NOTES**

- (1) Socket to be Underwriters Laboratory (UL) listed.
- (2) Connections for terminating service conductors shall be the lay-in type.
- (3) Service conduit to enter at point "A" or "B".
- (4) Meter shall be 4' 5' 6" from finished grade.
- (5) Commercial application for non-critical loads, i.e. sprinkler control and gates. PNM will allow socket without bypass handle.
- (6) PNM does not permit a trough ahead of meter socket.
- (7) Customer building numbers must be permanently painted on proper meter panels.

## REFERENCES

- (1) See DS-4-8.0 Overhead Permanent/Temporary Single-Phase
- (2) See DS-4-5.0 Underground Service Entrance System

Approved Equipment		
Manufacturer	Item	Mfg Part #
Milbank	100A OH/UG Ringless Socket	CP2A4101XGVZSRP1

For ease of checking service without interruption, PNM will no longer allow ring meter sockets as of 12/01/2013.

05/01/25