# 20-Year Transmission Planning Outlook

**PNM INTEGRATED PLANNING** 



**NOVEMBER 12, 2024** 

### **OVERVIEW & PURPOSE**

PNM presents its first ever 20-year transmission outlook offering a strategic overview of the transmission infrastructure to reliably achieve PNM's goal of 100% carbon-free energy by 2040. This outlook marks the <u>initial step</u> in identifying potential transmission concepts for the next two decades based on decarbonizing aligned with PNM's 2023 Integrated Resource Plan.

The purpose of this outlook is to initiate a conversation with a broad group of stakeholders, PNM recognizes collaboration is essential to achieve significant transmission expansion in New Mexico. PNM has not committed to building any of the projects or infrastructure identified herein. Additional studies and/or detailed evaluations are required to prioritize transmission expansion investment.

Disclaimer: The information contained in this outlook is based on the information known to PNM at the time it was created. PNM makes no representation or warranty of any kind as to the completeness, accuracy, reliability, suitability or availability as to the information contained herein. It is intended for illustrative or discussion purposes only and should not be relied upon or construed as a proposal, counterproposal, offer, contract, commitment, or any other form of legally binding document.



### NOVEMBER STAKEHOLDER MEETING

### AGENDA

- Standards of Conduct
- Study Objectives
- Methodology
- Modeling Assumptions
- Benefits of Transmission
- Study Results
- Cost and Schedule Estimates
- Next Steps
- Stakeholder Engagement





# OBJECTIVE

The 20-year transmission outlook serves as a foundational stage for future planning activities. It aims to:

#### Investigate Transmission for IRP Resources\*:

- Support IRP-identified resources such as wind energy, long-duration storage, and hydrogen generation.
- Address potential service needs based on PNM's updated load forecast.

#### Alleviate Local Area Constraints:

• Develop transmission solutions to mitigate constraints resulting from gas power plant retirements.

#### **Expand Beyond Traditional Planning**:

- Provide information typically outside the scope of traditional utility transmission planning processes.
- Extend considerations beyond the Integrated Resource Plan (IRP) for retail and the 10-Year Transmission Planning Study for PNM's Balancing Authority Area.
- Generate potential market interest in joint transmission development outside of the utility's Large Generator Interconnection Queue.

#### **Future Regional Planning:**

• Develop concepts for evaluation future regional planning processes, extending beyond those identified in the IRP.

### \*Current Trends and Policies and High Economic Growth per 2023 IRP Material Event update



### METHODOLOGY

#### **Three Point-in-Time Study Years**

- 2028 (near-term)
- 2033 (mid-term)
- 2040 (long-term)

#### Two Load Scenarios

- Current Trends and Policies
- High Economic Growth

#### **Two Generation Scenarios**

- Net Peak
- Maximum Renewable

The analysis was conducted using the following methodology:

- Methodology: Conducted studies using single contingency power flow (N-1) analysis
  - Study did not identify additional solutions for underlying system overloads, etc.
- Utilized the 2040 High Economic (HE) Net Peak and Maximum Renewable scenarios as the initial benchmarks, representing potential system conditions at the end of the 20-year planning horizon
- Each Project was assessed based on its effectiveness in reducing or eliminating thermal loading concerns

**Notes:** Prior to pursuing any investment, remaining planning analyses beyond this study including N-1-1, transient stability, short circuit analyses should be completed (and potentially electromagnetic transient or "EMT"). Additionally, PNM utilizes significant Grid Enhancing Technology (GETS) today and have extracted most latent capacity from system - Additional role for advanced conductor is possible but was outside the scope of this study



### STUDY ASSUMPTIONS

See April 2024 20-Year Plan Stakeholder presentation for additional details on study assumptions: <u>https://www.pnm.com/planning-for-the-future</u>

Initial Study Assumptions were adjusted to:

- Incorporate PNM's updated load forecast including expected economic development potential (May 2024)
- Simulate stressed generation scenarios on PNM's system
- Modified candidate project list
  - Deferred to future study: Sun Zia Interconnection due to modeling complexity required, and Southline, Vista Trails, Second Greenlee-Hidalgo-Luna 345 kV Line, and the Third Springerville-Greenlee 345 kV Line due to time constraints



### STUDY ASSUMPTIONS - BALANCING AREA LOAD

|               | 2024       | 2028  |        | 2033  |        | 2040  |        |
|---------------|------------|-------|--------|-------|--------|-------|--------|
| Load Scenario | Historical | СТР   | Growth | СТР   | Growth | СТР   | Growth |
| Peak          | 2,758      | 3,161 | 403    | 3,285 | 527    | 3,585 | 827    |
| Net Peak      | 2,620      | 3,003 | 383    | 3,121 | 501    | 3,406 | 786    |
| Max Renewable | 1,103      | 1,300 | 197    | 1,347 | 244    | 1,467 | 364    |

Future iterations of this study will seek to expand beyond these scenarios (e.g., gross peak case)

> CTP = Current Tends and Policies HEG = CTP + 370 MW by 2040



### STUDY ASSUMPTIONS - BALANCING AREA GENERATION





SLIDE 8 | NOVEMBER 12, 2024



### PNM System 20 Year Transmission Outlook

#### PNM 20 Year Plan

#### Station

- Expanded Station
- New Station

#### Transmission

- C Merchant
- ONew Line
- CCC Rebuild
  - PNM Planning Zones 3
- 💻 💻 PNM Planning Zones

Proprietary statement: This document and all previous issues are the property of hobic Service Company of New Mexico (PMM) and neither receipt nor possession matcher thereof, a service statement of the statement of the service of the service matcher thereof, a service statement, or any part thereof. Neither this document ner my formation constrained therein may be copied, reproduced, or otherwise used or disclosed to any other party without first obtaining the express written permission of PMM. This document is provided under the express condition that it will not be used in any way detimental to PMM.



### CONCEPTUAL TRANSMISSION PROJECTS

Load Serving: Helps integrate new load: Ensuring the infrastructure can handle additional demand Loadside Gas Retirement(s): Transitioning smoothly from loadside gas to alternative energy sources Market Access: Enhance Market Opportunities: Expand opportunities for buying/selling in regional market(s) Resilience: Increase supply resilience in extreme events

| Rio Puerco to Pajarito 345 kV Line                  | West Mesa-Ambrosia 230 kV Conversion to 345 kV |
|---|--|
| Pajarito to Prosperity 345 kV Line                  | Ambrosia-Coronado (AZ) 345 kV Line             |
| Ojo to Norton 345 kV Line                           | Union County-Springer 345 kV Line              |
| Four Corners-Rio Puerco 345 kV Line #2              | Union County-Comanche (CO) 345 kV Line         |
| Western Spirit-Hidden Mountain-Pajarito 345 kV Line | Union County-Taiban Mesa 345 kV Line           |
| Rio Sol Interconnection Transmission Project        | Taiban Mesa-Western Spirit 345 kV Line         |
| Sun Zia Merchant Transmission Project               | Chaves County-Western Spirit 345 kV Line       |

Deferred: Southline Merchant Transmission, Vista Trails Merchant Transmission, Second Greenlee-Hidalgo-Luna 345 kV Line, Third Springerville-Greenlee 345 kV Line



# RESULTS

### Net Peak

### Meeting Future Loads:

 Enabled PNM to deliver IRP resources effectively to meet projected future loads, including the High Economic Growth scenario.

### **Identified Overloads:**

 During certain contingencies, overloads were identified on the underlying 115 kV system in Albuquerque. Improvements will need to be identified to address these overloads.

### Max Renewable

#### **Increased Export Capacity:**

 Conceptual transmission projects allowed for the export of resources totaling twice the PNM Balancing Authority (BA) load.

#### **Current Export Capacity:**

- Currently, the system's export capacity is fully committed with existing resources.



### 2040 IRP CONCEPTUAL TRANSMISSION PORTFOLIO

|   | Conceptual Project  | Additional Load<br>serving* | Additional<br>Market<br>Access* | Enables IRP LDES-<br>Compressed Air<br>Storage and/or<br>Geothermal | Enables<br>IRP Wind<br>Delivery | Enables<br>Loadside Gas<br>Generation<br>Retirement | Addresses<br>Underlying<br>System Issues | Conceptual<br>IRP Role***  |
|---|---|-----------------------------|---------------------------------|---|---------------------------------|---|--|--|
| Ć | Rio Puerco-Pajarito 345 kV Line   | 300-600 MW                  | 0 MW                            | No  | No                              | Yes   | Yes                                      | Serve additional IRP<br>load forecasted<br>demand including<br>High Economic<br>Growth |
|   | Pajarito-Prosperity 345 kV Line   | 300-600 MW                  | 0 MW                            | No  | No                              | Yes   | Yes                                      | Serve additional IRP<br>load forecasted<br>demand including<br>High Economic<br>Growth |
|   | Rio Sol Interconnection to PNM  | 300-600 MW                  | 0 MW**                          | No**  | Yes                             | No  | No                                       | Potential Wind<br>Access and Load<br>Serving Capability                                |
| 7 | SunZia Interconnection to PNM   | 0 MW                        | Yes                             | No**  | No**                            | No  | No                                       | Potential Wind and<br>Market Access  |
|   | Western Spirit-Hidden Mountain-Pajarito 345 kV<br>Line #2                 | 300-600 MW                  | 0 MW**                          | No  | Yes                             | Yes   | No                                       | Potential Wind and<br>Load Serving<br>Capability                                       |
|   | Chaves County-Western Spirit 345 kV Line                                  | 0 MW                        | 600-1000<br>MW                  | Yes   | Yes                             | No  | No                                       | Potential<br>CAES/Geothermal<br>or Other Storage<br>Access                             |
|   | Four Corners-Rio Puerco 345 kV Line #2 (could<br>substitute w Ojo-Norton) | 600-1000 MW                 | 600-1000<br>MW                  | No  | No                              | Yes   | No                                       | Potential Hydrogen<br>or Storage Access<br>and Market Access                           |

Legend: Complimentary additions

\*Further study needed to validate maximum values beyond IRP forecasts

**\*\***When paired with certain other transmission solutions could create additional benefits

\*\*\* Enable additional carbon free energy



### ADDITIONAL RESULTS

|   | Other Conceptual Project Results   | Additional Load<br>serving | Additional Market<br>Access | Enables IRP LDES-<br>Compressed Air<br>Storage and/or<br>Geothermal | Enables IRP<br>Wind Delivery | Enables<br>Loadside Gas<br>Generation<br>Retirement | Addresses<br>Underlying<br>System<br>Issues |
|---|--|----------------------------|-----------------------------|---|------------------------------|---|---|
|   | West Mesa-Ambrosia 230 kV Line<br>Conversion to 345 kV   | 300-600 MW                 | 0 MW**                      | No  | No                           | No  | No  |
|   | Ambrosia-Coronado (AZ) 345 kV Line   | 300-600 MW                 | 600-1000 MW                 | No  | No                           | No  | No  |
|   | Taiban Mesa-Western Spirit 345 kV Line<br>(could pair well with HVDC expansion and<br>WST Line #2) | 0 MW**                     | 0 MW**                      | No**  | Yes**                        | No  | No  |
|   | Taiban Mesa-Union County-Comanche (CO)<br>345 kV Line  | 600-1000 MW                | Yes*                        | No**  | Yes**                        | No  | No  |
|   | Ojo-Norton 345 kV Line   | 300-600 MW                 | 200-500 MW                  | No  | No                           | Yes   | No  |
| Ċ | Union County-Springer 345 kV Line  | 0 MW**                     | 200-500 MW                  | No  | Yes**                        | No  | No  |



\*Further study needed to validate maximum values beyond IRP forecasts \*\*When paired with certain other transmission solutions could create additional benefits



### **BENEFITS OF NEW TRANSMISSION**

### Supports Additional Load Growth:

- Facilitates service to new load growth, including economic development opportunities.

#### **Increases Market Access:**

 Enhances access to regional markets, promoting efficient use of clean energy resources across a wide geographic area and improving resilience during extreme weather events.

#### Access to Renewable Resources:

 Provides increased access to New Mexico's abundant wind, solar, and other renewable energy resources.

#### Improves System Reliability and Resilience:

 Strengthens the system's ability to withstand planned or unplanned outages and extreme weather conditions.



### BENEFITS AND ENHANCEMENTS OF NEW TRANSMISSION

#### **Enables Fossil Generation Retirement:**

- Supports the future retirement of existing fossil fuel generation, particularly in loadconcentrated areas.
- Enables loadside gas retirements while maintaining system performance criteria under certain conditions.

#### Facilitates Advanced Conductor Rebuilds:

 Enables future deployment of advanced conductor rebuilds in ABQ metro area load center by sufficiently offloading existing lines, allowing for necessary outages during construction. Similar potential also exists elsewhere on system.



### **RESULTS - PRELIMINARY COST AND SCHEDULE ESTIMATES**



High level estimate provided to show the magnitude of the cost and time required to implement needed transmission.



Based on standard assumption and does not factor in project specific details like ROW procurement, permitting, and outages for construction.

Estimates are provided for evaluated projects excluding merchant transmission projects

Does not account for rapidly change long lead item procurement time frames.



### **RESULTS - PRELIMINARY COST AND SCHEDULE ESTIMATES**

| Conceptual Transmission Project                     | Total (\$M) in<br>'24\$ | Estimated Schedule<br>(Years) |
|---|-------------------------|-------------------------------|
| Rio Puerco-Pajarito 345 kV Line                     | 120-132                 | 4-5                           |
| Pajarito-Prosperity 345 kV Line                     | 65-72                   | 3.5-4.5                       |
| Rio Sol Interconnection to PNM                      | 170-185                 | 4-6                           |
| Western Spirit-Hidden Mountain-Pajarito 345 kV Line | 445-480                 | 5-7.5                         |
| SunZia Interconnection to PNM                       | 47-55*                  | 4-6                           |
| Chaves County-Western Spirit 345 kV Line            | 510-540                 | 7-10                          |
| Four Corners-Rio Puerco 345 kV Line #2              | 375-410                 | 8-10                          |
| Ojo-Norton 345 kV Line                              | 150-218                 | 5-7.5                         |
| West Mesa-Ambrosia 230 kV Line Conversion to 345 kV | 310-340                 | 7-8.5                         |
| Ambrosia-Coronado (AZ) 345 kV Line                  | 430-460                 | 7-9                           |
| Taiban Mesa-Western Spirit 345 kV Line              | 325-350                 | 6-8.5                         |
| Union County-Taiban Mesa 345 kV Line                | 400-430                 | 6-10                          |
| Union County-Comanche (CO) 345 kV Line              | 415-460                 | 8-10                          |
| Union County-Springer 345 kV Line                   | 160-180                 | 6-8.5                         |
| *Unknown required equipment/materials               |                         |                               |

Please note these are high-level estimates in 2024\$ based on indicative line routes. Detailed costs and schedules unknown until specific routes selected, permitting, ROW and easement, and engineering, procurement and construction bids obtained and contracted. These are subject to change based on permitting, easement, equipment, material, etc. cost escalations. As noted on previous slides some of these projects are compliments of each other.



### CONCEPTUAL PNM DECARBONIZATION ROAD MAP



Retirements: Afton Combine Cycle, Luna Energy Facility, Lordsburg, La Luz, and Rio Bravo, and expiration of Valencia PPA

All resources must be procured through a competitive RFP resource solicitation



### NEXT STEPS

Publish Final Report – Q1 2025 - <u>https://www.pnm.com/planning-for-the-future</u> Future Study Work

- **Continuous Improvement:** Continue to refine 20-year Planning Approaches for future studies and perform evaluations on a periodicity to support the IRP including, nodal modeling
- Incorporate insights from related studies: Evaluate the project in the context of findings from other relevant studies
- **Examine alternative scenarios**: Analyze additional scenarios to test projects against a wider range of probable system conditions
- **Expand analysis**: Quantify the maximum possible increased load-serving and export capacity resulting from the projects beyond IRP portfolio levels under all scenarios
- Evaluate Project Combinations: Assess combinations of projects to identify additional potential benefits

#### **Options for Developers**

• PNM welcomes developers to utilize the non-tariff wires-wires or FERC Large Generator Interconnection Processes to evaluate the project



# STAKEHOLDER FEEDBACK AND QUESTIONS

Send feedback and questions to pnm20yeartransmissionstudy@pnmresources.com

Feedback will help guide future study work and refine approaches



